



# BRICK & MORTAR RESEARCH LABORATORY

A trading division of Sharp & Howells Pty Ltd ACN 004 782 996 ABN 26 004 782 996

NATA Accredited Laboratory No 658

FACTORY 2, 2 HORNE ST HOPPERS CROSSING VIC 3029 PH/FAX: (03) 9369 8018 MOB: 0419 592 838 EMAIL: [bmrl@bigpond.com](mailto:bmrl@bigpond.com) WEBSITE: [bmrl.com.au](http://bmrl.com.au)

Page 1 of 2

## TEST CERTIFICATE NO 8358.3

DATE: 29/1/15

### PROPERTIES OF WALL TIES

CLIENT: Wilmaplex Pty Ltd  
57 Lathams Rd  
Carrum Downs Vic 3201

SAMPLE: WTBX8 GAL Z600 veneer face (stubby) wall ties. Galvanised nails for stud fixing supplied by the client.  
Source of sample: ties supplied by the client.

RECEIVED: 5/12/14

DATE OF TESTING: 20/1/15

### TEST

Determination of:

Strength of wall ties  
Resistance to water transfer

### METHOD OF TEST

AS/NZS 2699.1-2000 Appendix B  
AS/NZS 2699.1-2000 Appendix E

NATA Accredited Laboratory Number 658

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.  
Accredited for compliance with ISO/IEC 17025.



**Stuart Errey**  
MRACI, C Chem  
Manager

Test Certificate No 8358.3

29/1/15

**STRENGTH OF WALL TIES**

Cavity width: 50 mm

Location of test: Laboratory

Age of specimens when tested: 7 days

Frame end of tie nailed to section of MGP 10 timber stud, 90 x 45 mm.

**Strength in compression**

Specimen no	1	2	3	4	5	6
Applied load, kN	0.70	0.68	0.59	0.76	0.57	0.59

Abnormal results excluded: Nil

Reason for exclusion:

Characteristic strength in compression: 0.48 kN

Classification of tie: Medium duty

**Strength in tension**

Specimen no	7	8	9	10	11	12
Applied load, kN	0.27	0.29	0.31	0.30	0.27	0.24

Abnormal results excluded: Nil

Reason for exclusion:

Characteristic strength in tension: 0.20 kN

Classification of tie: Light duty

**RESISTANCE TO WATER TRANSFER**

Specimen no	13	14	15
Vertical displacement, mm	10	10	10
Water transfer ?	No	No	No

Classification of tie: Pass

Overall classification of tie: **Light Duty**